

Minimum LL lengths for SL pipe

last edit: 3/19/2010

	SL Bell x SL PE	SL PE x SL PE	SL Bell x Flg	SL PE x Flg
6"	1' 6"	1' 6"	1' 0"	1' 6"
8"	1' 6"	1' 6"	1' 0"	1' 6"
10"	1' 6"	1' 6"	1' 0"	1' 6"
12"	1' 6"	1' 6"	1' 0"	1' 6"
14"	1' 6"	2' 0"	1' 0"	2' 0"
16"	1' 6"	2' 0"	1' 0"	2' 0"
18"	1' 6"	2' 0"	1' 6"	2' 0"
20"	1' 6"	2' 0"	1' 6"	2' 0"
24"	2' 0"	2' 6"	3' 0"	2' 6"
30"	2' 6"	3' 0"	3' 0"	3' 0"

